



**King County
International Airport**
Department of
Construction & Facilities Management
P.O. Box 80245
Seattle, WA 98108
(206) 296-7380
(206) 296-0100 TDD
(206) 296-0190 FAX

File - Fire Marshall
CF
PSF 3 FMI A1

June 21, 2000

Jason Herring
Deputy Fire Marshall
Building Services Division
DDES
900 Oaksdale Ave. SW
Renton WA 98055

Dear Jason:

Listed below is an itemized status report of action items developed following your 19 May 2000 annual inspection of the King County International Airport terminal building.

1. ILLUMINATED EXIT SIGNS AND LIGHTING

Defective lighting has been repaired; signs are illuminated and lighting in good working order.

2. OPEN WIRING

Exposed wiring has been repaired.

3. CEILING TILES

Ceiling tiles have been reinstalled.

4. FIRE EXTINGUISHER SERVICING

All extinguishers in the terminal have been inspected and have current inspection tags.

5. HOUSEKEEPING ITEMS

All paint and other miscellaneous items have been removed from the stairwell area.

6. OCCUPANT BUILDING LOADS

Floor plans for both buildings were provided to Bill Scharer DDES Building Services Inspector as part of a related meeting. Mr. Scharer will calculate the floor areas for each area of the building and advise of the appropriate occupancy loads.

7. FIRE ALARM DUCT DETECTORS

The duct detectors have been inspected and are to be replaced. The Airport is in the final stages of procurement for the purchase and installation of the fire safety equipment.



8. AIRSIDE EXIT DOORS

A design for providing adequate airside security protection for the terminal doors has been developed. The Airport is presently arranging for procurement and installation of the building security hardware and associated equipment.

We are currently working to complete Items 7 and 8 above and anticipate finalizing this work in July. In order to fully comply with the inspection notice a 30 day extension to the completion date is requested. Please advise this office directly at your earliest convenience if this is acceptable.

Your continuing assistance in improving Airport fire safety is greatly appreciated.

Sincerely,

A handwritten signature in black ink, appearing to read "Mike Colmant". The signature is fluid and cursive, with the first name "Mike" and last name "Colmant" clearly distinguishable.

Mike Colmant
Assistant Airport Manager
King County International Airport

cc: ✓ Cynthia Stewart, Airport Manager, King County International Airport
Dave Walker, Captain, King County Airport Police/ARFF